

MISCELLANEOUS WATER TANK REPAIRS
FOR
CITY OF BRENTWOOD WATER SERVICES DEPARTMENT

ADDENDUM NO. 1

ISSUE DATE: February 18, 2014
BID DATE: March 4, 2014

SMITH SECKMAN REID, INC.
2995 Sidco Drive
Nashville, TN 37204
615/383-1113

SSR No. 10-41-022.0

ADDENDUM NO. 1
February 18, 2014

BID DATE: March 4, 2014

TO ALL CONTRACTORS AND SUPPLIERS:

The attention of all prospective bidders for the subject project is directed to the following additions, deletions and modification to the Contract Documents.

This Addendum consists of 4 pages, with the following attachments:

An attachment consisting of a Location Map.

Specifications

Addendum Item	Page or Drawing	Location and Description of Change
S-1	Section 00100 – Advertisement for Bids	REVISE the first paragraph of the Advertisements for Bids to read as follows: The City of Brentwood, Tennessee will receive sealed bids at the Brentwood Municipal Center, 5211 Maryland Way, in the Commissioner’s Chambers on the second floor, for the above referenced project, until 2:00 o’clock p.m., central time, on the 4th day of March, 2014 , at which time the bids will be publicly opened and read aloud.
S-2	Section 00200 – Instructions to Bidders	REVISE Article 15.04 of the Instruction to Bidders to read as follows: Mr. Chris Milton, P.E. City of Brentwood, TN Brentwood Municipal Center 5211 Maryland Way Brentwood, TN 37027

Addendum Item	Page or Drawing	Location and Description of Change
S-3	Section 00200 – Instructions to Bidders	<p>REVISE the first sentence of Article 15.07 of the Instruction to Bidders to read as follows:</p> <p>The City of Brentwood (herein called the “Owner”) invites bids on the form provided, all blanks of which must be appropriately filled in. Bids will be received by the Owner at 5211 Maryland Way, Brentwood, TN 37027, until 2:00 P.M., central standard time, on 4th day of March, 2014 and then at said time publicly opened and read aloud.</p>
S-4	Section 00400 – Bid Form	<p>REVISE THIS BID IS SUBMITTED TO:</p> <p>Mr. Chris Milton, P.E. City of Brentwood, TN Brentwood Municipal Center 5211 Maryland Way Brentwood, TN 37027</p>
Q-1	Question	<p>Question from Contractor:</p> <p>What is the average depth of the spalled areas on the roof? I am not 100% sure on the average depth of the spalled areas. From the pictures they look to be about 1/8” to 1/4” deep.</p>
Q-2	Question	<p>Question from Contractor:</p> <p>Is there any coating associated with this project? No. The contractor will be required to pressure wash the concrete tanks to remove visible oil, dirt and mildew.</p>
Q-3	Question	<p>Question from Contractor:</p> <p>Can you provide an address for each tank? See address, type and size below.</p>

<i>Tank Name</i>	<i>Address</i>	<i>Material</i>	<i>Dia.</i>	<i>Height</i>	<i>Volume</i>
Brentwood Park #1	248 Wilson Pike	Concrete	101’	33’	2,000,000
Brentwood Park #2	248 Wilson Pike	Concrete	101’	33’	2,000,000
Carriage Hills #1	1729 Coachman’s Court	Concrete	100’	34’	2,000,000
Carriage Hills #2	1729 Coachman’s Court	Concrete	122’	34’	3,000,000
Chenoweth	900 Green Hill Boulevard	Concrete	101’	33’	2,000,000
Raintree #1	9440 Eastwood Drive	Glass-Lined	24’	29’	103,000
Robert E. Lee	1313 Robert E. Lee Lane	Glass-Lined	42’	23’	239,000
Willowick	1528 High Oaks Court	Glass-Lined	31’	33’	185,000

END OF ADDENDUM NO. 1

Receipt of this Addendum should be indicated in the space provided on the Bid Form, and all Addenda should be affixed to the Inside of the front cover of the Contract Documents.

Smith Seckman Reid, Inc.
2995 Sidco Drive
Nashville, TN 37204
(615) 383-1113

